Fire Department Monthly SCBA Inspection Sheet

Date_____

SCBA Inspection Checklist

SCBA HARNESS

- Straps(Extended fully check for rips,tears)
- High Pressure Hose (connected to cylinder)
- Cylinder Pressure (change/refill if less than full)

TURN ON CYLINDER

- Check HUD Display for indicator lights
- Operate Purge Valve
- PASS activation (normal & manual)
- *CLOSE CYLINDER AND DRAIN SYSTEM*

FACE PIECE

- Straps(extended fully, check for rips, tears)
- Operate Voice Transmitter
- Check Rubber Seal and Nosecup for wear, rips
- Clean Face Piece if needed

IF ANY PROBLEMS ARE FOUND, TAKE UNIT OOS, REPORT TO AN OFFICER

Pack #	Cylinder Pressure	Cylinder Changed	Regulator OK	Facepiece OK	Cleaned	Entire Apparatus	Remarks	Inspected By

Fire Department Monthly SCBA Inspection Sheet

Date_____

Pack #	Cylinder Pressure	Cylinder Changed	Regulator OK	Facepiece OK	Cleaned	Entire Apparatus OK	Remarks	Inspected By